

Certificate of Compliance

Certificate Number **20110531-EX15637**
Report Reference **EX15637, 2010 June 9**
Issue Date **2011 May 31**

Page 1 of 1



Issued to: **ORTON S R L**

VIA DEI BAZACHI 50
29121 PIACENZA PC ITALY

*This is to certify that
representative samples of*

BUTTERFLY VALVES


Model DS Series, sizes 3(76.2), 4(114.3), 6(152.4), 8(203.2), 10(254),
12(304.8), 14(355.6), 16(406.4), 18(457.2), 20(508), 24(609.6)

*Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized
licensee of UL in accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: Butterfly Valves for Fire Protection Service, UL1091, 6th Edition

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>